



中国国家强制性产品认证证书



SITIAS
Worldwide Access

证书编号: 2021322307003971

认证委托人名称: 诺亚执行器有限公司
认证委托人地址: 韩国仁川市西区正西津9路11
生产者名称: 诺亚执行器有限公司
生产者地址: 韩国仁川市西区正西津9路11
生产企业名称: 诺亚执行器有限公司
企业地址: 韩国仁川市西区正西津9路11

产品名称: 电动执行机构
系列、规格、型号: NA 系列
标准: GB/T 3836.1-2021、GB/T 3836.2-2021

认证模式: 型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-C23-01:2019 《强制性产品认证实施规则 防爆电气》的要求, 特发此证。
产品相关信息详见附件。

发证日期: 2023年03月22日

有效期至: 2026年05月17日

首次发证日期: 2021年05月18日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准:

邵华



上海仪器仪表自控系统检验测试所有限公司

<http://www.sitias.com.cn>

中国·上海·漕宝路103号200233

电话: +86 21 64510844

S 0008731



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2021322307003971

APPLICANT: NOAH ACTUATION CO., LTD.
ADDRESS: 11, Jeongseojin 9-ro, Seo-gu, Incheon-si, 22850, Korea
MANUFACTURER: NOAH ACTUATION CO., LTD.
ADDRESS: 11, Jeongseojin 9-ro, Seo-gu, Incheon-si, 22850, Korea
FACTORY: NOAH ACTUATION CO., LTD.
ADDRESS: 11, Jeongseojin 9-ro, Seo-gu, Incheon-si, 22850, Korea

PRODUCT: ELECTRIC ACTUATOR
SERIES, SPECIFICATION, MODEL: NA Series
STANDARDS: GB/T 3836.1-2021, GB/T 3836.2-2021

Type of Certification: Type test + Initial inspection + Surveillance inspection

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).
Refer to the attachment for detailed information.

Valid from: March 22, 2023

Valid until: May 17, 2026

Date of original certification: May 18, 2021

The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiias.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0007030



中国国家强制性产品认证证书



SITIAS
Worldwide Access

证书编号: 2021322307003971

附 件

产品名称: 电动执行机构

型号规格:

NA *a-bc*

a 代表最大输出扭矩:

006 = 60 N·m; 009 = 90 N·m; 015 = 150 N·m; 019 = 190 N·m;
028 = 280 N·m; 038 = 380 N·m; 050 = 500 N·m; 060 = 600 N·m;
080 = 800 N·m; 100 = 1000 N·m; 120 = 1200 N·m;

b 代表输入电压:

B = 110 VAC, 50/60Hz, 单相;
D = 220 VAC, 50/60Hz, 单相;
G = 380 VAC, 50/60Hz, 三相;
I = 440 VAC, 50/60Hz, 三相;
J = 460 VAC, 50/60Hz, 三相;
K = 480 VAC, 50/60Hz, 三相;
M = 24 VDC;

c 代表软件控制选项:

A = 标准模式 (开关型);
B = ALS (辅助限位开关);
C = ATS (辅助扭矩开关);
D = PIU (可调电位器: 0~1kΩ);
E = CPT (阀位变送器: 4~20mA);
F = PCU (比例控制单元: 4~20mA);
O = EXT (行程扩展 120°, 135°, 180°, 270°, 300°);
L = Mod-Bus;
M = Profi-Bus;

防爆标志:

Ex db IIC T6...T4 Gb

批 准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号: 2021322307003971

附 件

电气参数: 输入电源: 单相, 50/60Hz, 110/220V 或者三相, 50/60Hz, 380V/440V/460V/480V 或者 24V 直流;
工作制为: S2 15min。
产品输出扭矩: 60 N·m~1200 N·m。

相关报告编号: 2023S17402-010743, 2021S17402-005285

使用条件:

1. 特殊(限制)使用条件:
 - 1) 有关防爆接合面的详细信息, 请咨询制造商;
 - 2) 上盖紧固件的性能等级为 A2-50;
 - 3) 产品使用环境温度: $-40^{\circ}\text{C} \sim +55^{\circ}\text{C}$ for T6, $-40^{\circ}\text{C} \sim +70^{\circ}\text{C}$ for T5, T4;

批 准:



上海仪器仪表自控系统检验测试所有限公司