



中国国家强制性产品认证证书



证书编号: 2021322307003972

认证委托人名称: 诺亚执行器有限公司
认证委托人地址: 韩国仁川市西区正西津9路11
生产者名称: 诺亚执行器有限公司
生产者地址: 韩国仁川市西区正西津9路11
生产企业名称: 诺亚执行器有限公司
企业地址: 韩国仁川市西区正西津9路11

产品名称: 电动执行机构
系列、规格、型号: SA 系列
标准: GB/T 3836.1-2021、GB/T 3836.2-2021

认证模式: 型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-C23-01:2019 《强制性产品认证实施规则 防爆电气》的要求, 特发此证。
产品相关信息详见附件。

发证日期: 2023年03月22日

有效期至: 2026年05月17日

首次发证日期: 2021年05月18日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准:



上海仪器仪表自控系统检验测试所有限公司

<http://www.sitias.com.cn>

中国·上海·漕宝路103号200233

电话: +86 21 64510844

S 0008730



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2021322307003972

APPLICANT: NOAH ACTUATION CO., LTD.
ADDRESS: 11, Jeongseojin 9-ro, Seo-gu, Incheon-si, 22850, Korea
MANUFACTURER: NOAH ACTUATION CO., LTD.
ADDRESS: 11, Jeongseojin 9-ro, Seo-gu, Incheon-si, 22850, Korea
FACTORY: NOAH ACTUATION CO., LTD.
ADDRESS: 11, Jeongseojin 9-ro, Seo-gu, Incheon-si, 22850, Korea

PRODUCT: Electric Actuator
SERIES, SPECIFICATION, MODEL: SA Series
STANDARDS: GB/T 3836.1-2021、GB/T 3836.2-2021

Type of Certification: Type test + Initial inspection + Surveillance inspection

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).
Refer to the attachment for detailed information.

Valid from: March 22, 2023

Valid until: May 17, 2026

Date of original certification: May 18, 2021

The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiilas.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0007029



中国国家强制性产品认证证书



证书编号: 2021322307003972

附 件

产品名称: 电动执行机构

型号规格: SA a X - b c

a 代表输出扭矩:

05 = 50 N·m;

09 = 90 N·m;

b 代表输入电压:

B = 110VAC 50/60Hz 单相;

D = 220VAC 50/60Hz 单相;

E = 230VAC 50/60Hz 单相;

L = 24VAC 50/60Hz 单相;

M = 24VDC;

N = 12VDC;

X = 48VDC;

c 代表软件控制选项:

A = 标准模式 (开关型);

D = PIU (可调电位器: 0~1kΩ);

F = PCU (比例控制单元: 4~20mA);

G = LCU (就地控制单元);

E = CPT (阀位变送器: 4~20mA);

L = Mod-Bus;

M = Profi-Bus;

N = Can-Bus;

T = SCP (超级电容模式);

防爆标志: Ex db IIB T6 Gb

批 准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号: 2021322307003972

附 件

电气参数: 输入电源为单相, 50/60Hz, 110/220/230VAC 或 24VAC, 或 12/24/48VDC
输出扭矩: 50 N·m、90 N·m
工作制: S2 15min

相关报告编号: 2023S17402-010742, 2021S17402-005286

使用条件:

1. 特殊(限制)使用条件:
 - 1) 有关防爆接合面的详细信息, 请咨询制造商;
 - 2) 上盖紧固件的性能等级为 A2-50;
 - 3) 执行机构的安装只能为垂直或水平方向, 执行机构不可以倒立安装;
 - 4) 产品使用环境温度: $-20^{\circ}\text{C} \sim +55^{\circ}\text{C}$;

批 准:



上海仪器仪表自控系统检验测试所有限公司