

Certificate of Conformity

- (1)
- (2) Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres – **Directive 2014/34/EU**

- (3) Certificate Number:

EPS 18 ATEX 1 216 X

Revision 1

- (4) Equipment: Actuator type RedMax-***
- (5) Manufacturer: Schischek GmbH
- (6) Address: Mühlsteig 45, Gewerbegebiet Süd 5
90579 Langenzenn
Germany

- (7) This equipment and any acceptable variation thereto are specified in the schedule to this Certificate of Conformity and the documents therein referred to.
- (8) Bureau Veritas Consumer Products Services Germany GmbH certifies based on a voluntary assessment that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II of the Directive 2014/34/EU. The examination and test results are recorded in the confidential documentation under the reference number 18TH0505.
- (9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN IEC 60079-0:2018

EN 60079-1:2014

EN 60079-11:2012

EN 60079-31:2014

- (10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.
- (11) This Certificate of Conformity relates only to the design and the construction of the specified equipment in accordance with Directive 2014/34/EU. Further requirements of this Directive apply to the manufacture and supply of this equipment. Those requirements are not covered by this certificate.
- (12) The marking of the equipment shall include the following:

II 3 (3) G Ex db [ic Gc] IIC T6, T5, T4 Gc

II 3 (3) D Ex tc [ic Dc] IIIC T80°C, T95°C, T130°C Dc

Certification department of explosion protection

Hamburg, 2020-11-24

H. Schaffer

Page 1 of 3

Certificates without signature and seal are void. This certificate is allowed to be distributed only if not modified. Extracts or modifications must be authorized by Bureau Veritas Consumer Products Services Germany GmbH. EPS 18 ATEX 1 216 X, Revision 1.

(13)

Annexe

(14) **Certificate of Conformity EPS 18 ATEX 1 216 X**

Revision 1

(15) Description of equipment:

The actuator type RedMax-*** consists of a flameproof enclosure with actuator shafts that accommodate electromechanical components. The internal portion is temperature controlled. The flameproof enclosure is mounted in a protective housing together with additional mechanical components. The gears and mechanical actuators mounted in the protective housing do not form part of this type approval.

Connection is by means of a connecting lead (open-ended line).

Electrical data:

Power supply: terminals 1-5 (X1, XA)

Nominal voltage U_0/U	up to	24 – 240 V
Rated voltage	max.	240 V
Rated current	max.	2.5 A

Option –S terminals 1-6 (XB)

Nominal voltage U_0/U	up to	24- 230 V
Rated voltage	max.	240 V
Rated current	max.	5.0 A

Option –Y terminals 1-6 (X2, XB)

Nominal voltage U_0/U	up to	24 V
Rated voltage	max.	24 V
Rated current	max.	30 mA

Rated values are maximum values, the actual electrical values are determined by mounted electrical apparatus. Within these limiting values complying with the appropriate standards, the manufacturer specifies the final limiting values dependent on power supply specifications, operating mode, utilization category, etc. Any additional technical features are specified in the test documents and the operating manual.

Ambient temperature	T6	-40 °C up to +40 °C
	T5	-40 °C up to +50 °C
	T4	-40 °C up to +60 °C

Certificate of Conformity EPS 18 ATEX 1 216 X

Revision 1

Intrinsic safe circuits

Option –BF, terminals 1,2 (EEXi output, JP101)

U_o 5.88 V
 I_o 24.75 mA
 P_o 0.037 W

Linear circuit

Li negligible

Ci negligible

Maximum of external lumped capacitance and inductance:

	IIC	Ex ic	
		IIB	IIA
Lo	50 mH	50 mH	50 mH
Co	43 µF	1000 µF	1000 µF

RS232, terminals 1-6 (EEXi output, SV101)

U_o 5.88 V
 I_o 119 mA
 P_o 0.7 W

Linear circuit

Li negligible

Ci negligible

Maximum of external lumped capacitance and inductance:

	IIC	Ex ic	
		IIB	IIA
Lo	2 mH	2 mH	2 mH
Co	43 µF	1000 µF	1000 µF

(16) Reference number: 18TH0505

(17) Schedule of Limitations:

For repair of the flameproof joints due regard must be given to the structural specifications provided by the manufacturer. Repair based on the values in tables 2 and 3 of EN 60079-1 is not accepted.

The actuator shall be used only together with certified enclosure provided by Schischek.

(18) Essential health and safety requirements:

Met by standards



Certification department of explosion protection

H. Schaffer

Hamburg, 2020-11-24