

## **IECEx Certificate** of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION **IEC Certification Scheme for Explosive Atmospheres**

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:

IECEx BAS 11.0048

issue No.:5

Status:

Current

Date of Issue:

2016-05-31

Page 1 of 4

Issue No. 4 (2015-9-2) Issue No. 3 (2015-3-20) Issue No. 2 (2014-7-11) Issue No. 1 (2014-1-15) Issue No. 0 (2011-6-28)

Issue No. 5 (2016-5-31)

Certificate history:

Applicant:

**Bifold Fluidpower Limited** 

Broadgate

Oldham Broadway Business Park

Chadderton Oldham

**Greater Manchester** 

OL9 9XA

**United Kingdom** 

Electrical Apparatus:

Optional accessory:

EXD2010 Electro-hydraulic Positioning System

Type of Protection:

Flameproof & Dust tight

Marking:

Ex d IIC T6\* Gb (-40°C  $\leq$  Ta  $\leq$  +60°C)\* Ex tb IIIC T85°C\* Db (-40°C  $\leq$  Ta  $\leq$  +60°C)\* IP66 - \* see schedule

Approved for issue on behalf of the IECEx

Certification Body:

R S Sinclair

Position:

Technical Manager

Signature:

(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.

2. This certificate is not transferable and remains the property of the issuing body.

3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

**SGS Baseefa Limited Rockhead Business Park** Staden Lane **Buxton** Derbyshire **SK17 9RZ** United Kingdom





# IECEx Certificate of Conformity

Certificate No.:

IECEx BAS 11.0048

Date of Issue:

2016-05-31

Issue No.: 5

Page 2 of 4

Manufacturer:

**Bifold Fluidpower Limited** 

Broadgate

Oldham Broadway Business Park

Chadderton Oldham

Greater Manchester

OL9 9XA

**United Kingdom** 

Additional Manufacturing location (s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0: 2011

Explosive atmospheres - Part 0: General requirements

Edition: 6.0

IEC 60079-1: 2007-04

Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"

Edition: 6

IEC 60079-31: 2008

Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure 't'

Edition: 1

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

#### **TEST & ASSESSMENT REPORTS:**

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

GB/BAS/ExTR11.0098/00 GB/BAS/ExTR15.0231/00 GB/BAS/ExTR14.0006/00 GB/BAS/ExTR16.0142/00 GB/BAS/ExTR14.0105/00

**Quality Assessment Report:** 

GB/BAS/QAR07.0038/05



## **IECEx Certificate** of Conformity

Certificate No.:

IECEx BAS 11.0048

Date of Issue:

2016-05-31

Issue No.: 5

Page 3 of 4

#### Schedule

#### **EQUIPMENT:**

Equipment and systems covered by this certificate are as follows:

The EXD2010 Electro-hydraulic Positioning System comprises a cylindrical enclosure to IECEx SIR 08.0025U, with a solid or glazed cover. The cover is secured to the enclosure base by a threaded joint complete with a locking screw. Internal and external earthing facilities are provided.

The interior of the enclosure comprises an assembly of several circular printed circuit boards, all mounted on pillars from a steel baseplate. The internal PCB assembly may be any one of four optional arrangements, either as standard DC units (rated up to 28V d.c. and 100mA, with a maximum internal dissipation of 2.8W), or optional AC units (rated up to 250V a.c. and 90mA, with a maximum internal dissipation of 22.5W) as follows:-

- a. The EX200 Positioner (d.c. supply)
- b. The EX210 Positioner (d.c. supply)
- c. The EX200 AC SC Positioner (a.c. supply) d. The EX210 AC SC Positioner (a.c. supply)

The D.C. units (i.e. for use with a d.c. supply) have a temperature marking of T85°C, whilst the A.C. units (i.e. for use with an a.c. supply) have a temperature marking of T100°C.

The enclosure base includes three off %" NPT or M20 cable entries for the accommodation of flameproof cable entry devices, with or without the interposition of a flameproof thread adapter. Unused entries are to be fitted with suitable certified flameproof stopping plugs. The cable entry devices, thread adapters and stopping plugs shall be suitable for the equipment, the cable and the conditions of use and shall be certified as Equipment (not a Component).

When the equipment is used in dust applications the cable entries must be sealed in accordance with IEC60079-14, to maintain the IP66 rating.

| co | NDITIONS OF CERT | IFICATION: NO |  |      |
|----|------------------|---------------|--|------|
|    |                  |               |  |      |
|    |                  |               |  |      |
|    |                  |               |  |      |
|    |                  |               |  |      |
|    |                  |               |  |      |
|    |                  |               |  |      |
|    |                  |               |  |      |
|    |                  |               |  |      |
|    |                  |               |  |      |
|    |                  |               |  |      |
|    |                  |               |  |      |
|    |                  |               |  |      |
|    |                  |               |  |      |
|    |                  |               |  | <br> |



# **IECEx Certificate** of Conformity

| _        |      |       |      |  |
|----------|------|-------|------|--|
| ( ``     | rtit | icate | NIO. |  |
| $\sim$ e | ıuı  | ivale | INC  |  |

IECEx BAS 11.0048

Date of Issue:

2016-05-31

Issue No.: 5

Page 4 of 4

### DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

#### Variation 5.1

| xTR: GB/BAS/ExTR16.0142/00  | File Reference: 16/0337 |  |
|-----------------------------|-------------------------|--|
| ATT. GDIDAGIENTICIO.0142/00 | The Reference. 10/0337  |  |
|                             |                         |  |
|                             |                         |  |
|                             |                         |  |
|                             |                         |  |
|                             |                         |  |
|                             |                         |  |
|                             |                         |  |
|                             |                         |  |
|                             |                         |  |
|                             |                         |  |
|                             |                         |  |
|                             |                         |  |
|                             |                         |  |
|                             |                         |  |
|                             |                         |  |
|                             |                         |  |
|                             |                         |  |
|                             |                         |  |
|                             |                         |  |