CHECK LIST

Checking actuator settings requires the use of and keys only. Displays on actuator show set values. Return to the start of the setting procedure (Position Display) by pressing and together. Checking may be carried out with the actuator in either Setting or Checking mode.



Until C1 (DIRECTION TO CLOSE) is displayed





To display C2 (CLOSE ACTION)







To display C3 (OPEN ACTION)







To display t C (TORQUE VALUE CLOSING)



Display shows selected torque



To display t C (TORQUE VALUE CLOSING)



Display shows selected torque

Press and together to return to Position Display and move valve to fully closed condition checking that closed symbol and lamp appear just as the limit of travel is reached.

Move valve to fully open position checking that open symbol and lamp appear just as the limit of travel is reached.

UK Head Office

Rotork Controls Limited Brassmill Lane Bath BA1 3JQ England Tel: +44 (0) 1225 733200

Fax: +44 (0) 1225 733200 Fax: +44 (0) 1225 333467 Email: mail@rotork.co.uk

USA Head Office

Rotork Controls Inc 675 Mile Crossing Blvd Rochester NY 14624 USA Tel: +1 585 328 1550 Fax: +1 585 328 5848 Email: info@rotork.com

A listing of Rotork worldwide can be found on http://www.rotork.com

ROTORK RANGE BASIC SETTING INSTRUCTIONS Actuator Indicator Display Window Hold setting tool directly in front of indicator window. Range 0.5 metres (18 inches) Across Key Plus Key Red Local / Stop / Remote Selector. Select to "Local" Setting Tool Down Key (Minus Key Enter Key These instructions enable the actuator to be configured to suit the valve and must be carried out before electrical start up. For complete instructions see Publication E170E. **PUBLICATION E171E ISSUE 03/01**





Switch on actuator power supply - select Local control. Setting may take place with display indicating closed, mid travel or open. Display will not indicate true position until position limit settings have been completed.

When using the setting tool press key until display changes












TOROUE AND POSITION









Default password is I d - do not change

Bar indicators appear confirming that setting mode has been entered. If bar indicators are not displayed, the actuator is in checking mode and settings cannot be changed.





Site configuration of indication and control options (see Publication E170E)


































tO (TORQUE VALUE OPENING)








LC (LIMIT CLOSED)



Manually operate the actuator to the fully closed position and back-off half to one turn of the actuator output.



Manually operate the actuator to the fully open position and back-off half to one turn of the actuator output.



When the is pressed the bars will flash and the appropriate indicator lamp will be illuminated.



Initial actuator settings are now complete and it is possible to operate the actuator electrically. It is possible to return to the position display from anywhere in the setting procedure by pressing ... and ... together.

