



# 中国国家强制性产品认证证书



证书编号：2020322307001142

认证委托人名称： Rotork Controls Limited  
 认证委托人地址： Rotork House, Brassmill Lane, Bath, BA1 3JQ, United Kingdom  
 生产者名称： Rotork Controls Limited  
 生产者地址： Rotork House, Brassmill Lane, Bath, BA1 3JQ, United Kingdom  
 生产企业名称： Rotork Controls Limited  
 企业地址： Rotork House, Brassmill Lane, Bath, BA1 3JQ, United Kingdom

产品名称： 执行器  
 系列、规格、型号： IQ 系列  
 标准： GB 3836.1-2010、GB 3836.2-2010、GB 3836.3-2010、  
 GB 12476.1-2013、GB 12476.5-2013

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求，特发此证。

发证日期：2020年9月9日                      有效期至：2025年9月8日

首次发证日期：2020年9月9日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



批准：



## 上海仪器仪表自控系统检验测试所有限公司

<http://www.sitias.com.cn>

中国·上海·漕宝路103号200233

电话：+86 21 64510844

S 0001198



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



**CERTIFICATE NO: 2020322307001142**

**APPLICANT:** Rotork Controls Limited  
**ADDRESS:** Rotork House, Brassmill Lane, Bath, BA1 3JQ, United Kingdom  
**MANUFACTURER:** Rotork Controls Limited  
**ADDRESS:** Rotork House, Brassmill Lane, Bath, BA1 3JQ, United Kingdom  
**FACTORY:** Rotork Controls Limited  
**ADDRESS:** Rotork House, Brassmill Lane, Bath, BA1 3JQ, United Kingdom

**PRODUCTNAME:** Electric Valve Actuators  
**SERIES,SPECIFICATION,MODEL:** IQ range  
**STANDARDS:** GB 3836.1-2010、GB 3836.2-2010、GB 3836.3-2010、  
 GB 12476.1-2013、GB 12476.5-2013

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

**Valid from:**September 9, 2020

**Valid until:** September 8, 2025

**Date of original certification:**September 9, 2020

**The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.**

This certificate is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



**APPROVAL:**   
 Xu JianPing



**Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.**

<http://www.sitiias.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0000768



# 中国国家强制性产品认证证书



**SITIiAs**  
Worldwide Access

证书编号：2020322307001142

## 附 件

产品名称： 执行器

型号规格： IQ10, IQ12, IQ18, IQ19, IQ20, IQ25, IQ35, IQ40, IQ70, IQ90, IQ95, IQ91, IQS12, IQS20, IQS35, IQM10, IQM12, IQM20, IQM25, IQM35, IQD10, IQD12, IQD18, IQD20, IQD25, IQH20, IQH25, IQH35, IQH40

防爆标志： Ex d IIB T4 Gb;  
Ex d e IIB T4 Gb;  
Ex tD A21 IP64 T120°C

电气参数： 三相200~600VAC, 50/60Hz  
单相110~240±10%VAC, 50/60Hz  
24VDC

批 准：



上海仪器仪表自控系统检验测试所有限公司



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



No. : 2020322307001142

## Attachment

**Product:** Electric Valve Actuators

**Model:** IQ10, IQ12, IQ18, IQ19, IQ20, IQ25, IQ35, IQ40, IQ70, IQ90, IQ95, IQ91, IQS12, IQS20, IQS35, IQM10, IQM12, IQM20, IQM25, IQM35, IQD10, IQD12, IQD18, IQD20, IQD25, IQH20, IQH25, IQH35, IQH40

**Ex marking:** Ex d IIB T4 Gb;  
Ex d e IIB T4 Gb;  
Ex tD A21 IP64 T120°C

**Electrical Parameter:** 200 to 600 VAC, three-phase, 50 or 60 Hz  
110 to 240±10% VAC, single-phase, 50 or 60 Hz  
24VDC

APPROVAL:

Xu JianPing



**Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.**