



中国国家强制性产品认证证书



证书编号：2020322304000945

认证委托人名称： Rotork Controls Limited
 认证委托人地址： Rotork House, Brassmill Lane, Bath, BA1 3JQ, United Kingdom
 生产者名称： Rotork Controls Limited
 生产者地址： Rotork House, Brassmill Lane, Bath, BA1 3JQ, United Kingdom
 生产企业名称： Rotork Controls Limited
 生产企业地址： Rotork House, Brassmill Lane, Bath, BA1 3JQ, United Kingdom

产品名称： 就地控制站

系列、规格、型号： RHS

标准： GB 3836.1-2010、GB 3836.2-2010、GB 12476.1-2013、
GB 12476.5-2013

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求，特发此证。

发证日期：2020年9月1日 有效期至：2025年8月31日

首次发证日期：2020年9月1日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准：



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322304000945

APPLICANT: Rotork Controls Limited

ADDRESS: Rotork House, Brassmill Lane, Bath, BA1 3JQ, United Kingdom

MANUFACTURER: Rotork Controls Limited

ADDRESS: Rotork House, Brassmill Lane, Bath, BA1 3JQ, United Kingdom

FACTORY: Rotork Controls Limited

ADDRESS: Rotork House, Brassmill Lane, Bath, BA1 3JQ, United Kingdom

PRODUCTNAME: Remote Hand Station

SERIES,SPECIFICATION,MODEL: RHS

STANDARDS: GB 3836.1-2010、 GB 3836.2-2010、 GB 12476.1-2013、
GB 12476.5-2013

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from:September 1, 2020

Valid until: August 31, 2025

Date of original certification:September 1, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



No. : 2020322304000945

Attachment

Product: Remote hand station

Model: RHS

Ex marking: Ex d IIB T4 Gb;
Ex tD A21 IP67 T120°C

Electrical Parameter: 24VDC, 1.0A

APPROVAL:

Xu JianPing



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.



中国国家强制性产品认证证书



SITIiAS
Worldwide Access

证书编号: 2020322304000945

附件

产品名称: 就地控制站

型号规格: RHS

防爆标志: Ex d IIB T4 Gb;
Ex tD A21 IP67 T120°C

电气参数: 24VDC, 1.0A

批准:



上海仪器仪表自控系统检验测试所有限公司