

**UK Type Examination
Certificate****CML 21UKEX1123X****Issue 0****United Kingdom Conformity Assessment**

1 Product or Protective System Intended for use in Potentially Explosive Atmospheres UKSI 2016:1107 (as amended by UKSI 2019:696) – Schedule 3A, Part 1

2 Equipment **Remote Hand Station**

3 Manufacturer **Rotork Controls Limited** **Rotork Controls, Inc.** **Rotork UK Ltd.**

4 Address **Brassmill Lane,
Bath, BA1 3JQ,
United Kingdom** **675 Mile Crossing Blvd,
Rochester,
NY 14624,
USA** **9 Brown Lane West,
Holbeck, Leeds,
LS12 6BH
United Kingdom**

5 The equipment is specified in the description of this certificate and the documents to which it refers.

6 Eurofins E&E CML Limited, Newport Business Park, New Port Road, Ellesmere Port, CH65 4LZ, United Kingdom, Approved Body Number 2503, in accordance with Regulation 43 of the Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres Regulations 2016, UKSI 2016:1107 (as amended by UKSI 2019:696), certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Schedule 1 of the Regulations.

The examination and test results are recorded in the confidential reports listed in Section 12.

7 If an 'X' suffix appears after the certificate number, it indicates that the equipment is subject to conditions of safe use (affecting correct installation or safe use). These are specified in Section 14.

8 This UK Type Examination certificate relates only to the design and construction of the specified equipment. Further requirements of the Regulations apply to the manufacturing process and supply of the product. These are not covered by this certificate.


9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the confidential report, has been demonstrated through compliance with the following documents:

EN IEC 60079-0:2018

EN 60079-1:2014

EN 60079-31:2014

10 The equipment shall be marked with the following:

 II 2GD

For marked code and ambient temperature range refer to CML 19ATEX1195X Issue 1.



CML 21UKEX1123X
Issue 0

11 Description

For product description refer to attached certificate CML 19ATEX1195X Issue 1.

12 Certificate history and evaluation reports

Issue	Date	Associated report	Notes
0	17 May 2021	R13837H/00	The issue of prime certificate.

Note: Drawings that describe the equipment are listed in the Annex.

13 Conditions of Manufacture

For conditions of manufacture refer to attached certificate CML 19ATEX1195X Issue 1.

Any routine tests/verifications required by the ATEX certification shall be conducted.

14 Specific Conditions of Use

For specific conditions of use refer to attached certificate CML 19ATEX1195X Issue 1.

Certificate Annex

Certificate Number CML 21UKEX1123X
Equipment Remote Hand Station
Manufacturer Rotork Controls Limited
Rotork Controls, Inc.
Rotork UK Ltd.



The following documents describe the equipment defined in this certificate:

Issue 0

Drawing No	Sheets	Rev	Approved date	Title
AD1429	1 to 6	6	17 May 2021	General assembly & nameplate drawing



EU Type Examination Certificate CML 19ATEX1195X Issue 1

- 1 Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU
- 2 Equipment **Remote Hand Station**
- 3 Manufacturer **Rotork Controls Limited** **Rotork Controls, Inc.** **Rotork UK Ltd.**
- 4 Address **Brassmill Lane,
Bath, BA1 3JQ,
United Kingdom** **675 Mile Crossing
Blvd, Rochester,
NY 14624,
USA** **9 Brown Lane West,
Holbeck, Leeds,
LS12 6BH
United Kingdom**
- 5 The equipment is specified in the description of this certificate and the documents to which it refers.
- 6 CML B.V., Chamber of Commerce No 6738671, Hoogoorddreef 15, Amsterdam, 1101 BA, The Netherlands, Notified Body Number 2776, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 12.


- 7 If an 'X' suffix appears after the certificate number, it indicates that the equipment is subject to conditions of safe use (affecting correct installation or safe use). These are specified in Section 14.
- 8 This EU Type Examination certificate relates only to the design and construction of the specified equipment or component. Further requirements of Directive 2014/34/EU Article 13 apply to the manufacture of the equipment or component and are separately certified.
- 9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the confidential report, has been demonstrated through compliance with the following documents:

EN IEC 60079-0:2018

EN 60079-1:2014

EN 60079-31:2014

- 10 The equipment shall be marked with the following:



II 2GD

Ex db IIB T4 Gb IP66/IP68^③

Ex tb IIIC T135°C Db

Ta = -^①°C to +^②°C

^①down to -50°C, ^②up to +70°C

^③Only IP6X is endorsed by CML

R C Marshall
Certification Officer



**CML 19ATEX1195X
Issue 1**

11 Description

The Remote Hand Station (RHS) is the electrical enclosure and associated display and control circuitry from a Rotork Actuator incorporated with an appropriate back-housing that includes field wiring facilities so that it can be mounted remotely from an actuator. This allows an operator to monitor and control a Rotork Actuator which is mounted in an inaccessible location.

The RHS comprises an electrical control and terminal enclosure attached via a common back-housing casting. The back-housing casting is manufactured in aluminium alloy and provides the back-housing for two electrical enclosures, all of which are designed to satisfy the requirements for flameproof equipment.

The electrical enclosure is formed by a cover which connects to the back-housing casting by means of a spigoted flamepath joint and is secured by four M8 socket cap-head screws. The electrical enclosure can be provided in two lengths, short and extra-short and contains monitoring and control circuitry. At one end of the electrical enclosure a window is provided to allow the observation of an internal LCD device. The window is manufactured from toughened glass and potted into the electrical cover. The electrical enclosure has external, non-penetrative local controls.

The terminal enclosure is formed by a cover which connects to the back-housing casting by means of a spigoted flamepath joint and is secured by three M5 socket cap-head screws. The terminal enclosure provides all electrical field wiring terminals. A single threaded entry point is provided for the installation of a suitable cable entry facility. The volumes of the terminal enclosure and the electrical enclosure are separated by a potted, cable feed-through bushing.

Notes:

- i. Sira 14ATEX1185X is superseded by this certificate.
- ii. The product covered by Issue 0 of this certificate remains identical to that previously covered by Sira 14ATEX1185X.
- iii. Where Sira 14ATEX1185X is specified in other product certification, or other technical specifications, this certificate reference for the product shall be used in its place; updating of the other product certificate or technical specification is not required.

Variation 1

This variation introduced the following modifications:

- i. Correction of typographical errors in the schedule drawings.
- ii. Addition of new drawings for clarity.

12 Certificate history and evaluation reports

Issue	Date	Associated report	Notes
0	26 Jun 2019	R12481A/00	Issue of Prime Certificate
1	02 Apr 2020	R13111A/00	Introcution of Variation 1

Note: Drawings that describe the equipment or component are listed in the Annex.



**CML 19ATEX1195X
Issue 1**

13 Conditions of Manufacture

The following conditions are required of the manufacturing process for compliance with the certification.

- i. Where the product incorporates certified parts or safety critical components the manufacturer shall ensure that any changes to those parts or components do not affect the compliance of the certified product that is the subject of this certificate.
- ii. Each Remote Hand Station shall be subject to a routine overpressure test in accordance with EN 60079-1 clause 16 at the following values:

Routine overpressure tests Tamb below -20°C

Equipment	Test Pressure (bar)
With Short Electrical Cover	
Back Housing/Electrical Enclosure - Aluminium Alloy to BS1490, Grade: LM25TF (heat treated) (or equivalent)	14.91
With Extra-Short Electrical Cover	
Back Housing/Electrical Enclosure - Aluminium Alloy to BS1490, Grade: LM25TF (heat treated) (or equivalent)	14.96

14 Specific Conditions of Use (Special Conditions)

The following conditions relate to safe installation and/or use of the equipment.

- i. The Remote Hand Station shall be installed such that the risk of impact to the window is low.
- ii. WARNING – There is the risk of potential electrical charging hazard associated with the external non-metallic parts including the coating; see user instructions.
- iii. The grades of the fasteners securing the cover are indicated in the table below, if these fasteners are replaced in service the correct fastener grade must be used:

Location	Grade
Electrical Cover/Back Housing	A4-80 (ISO 3506-1)
Terminal Cover/Back Housing	12.9 (ISO 10642)

- iv. In accordance with the requirements of EN 60079-1 clause 5.1, the critical dimensions of the flamepaths are as follows:

Flamepath	Max. Gap (mm)	Min L (mm)
Electrical Cover/Back Housing	0.15	26.0
Terminal Cover/Back Housing	0.15	12.5
Cable Feed-Through Bush/Back Housing	0.15	25.0

Certificate Annex

Certificate Number CML 19ATEX1195X
Equipment Remote Hand Station
Manufacturer Rotork Controls Limited
Rotork Controls, Inc.
Rotork UK Ltd.



The following documents describe the equipment or component defined in this certificate:

Issue 0

Drawing No	Sheets	Rev	Approved date	Title
AD1429	1 to 6	4	26 Jul 2019	Remote Hand Station, ATEX & IECEX Groups IIB & IIC
PLAD1429	1 to 4	3	26 Jul 2019	Parts List for Remote Hand Station ATEX & IECEX Groups IIB & IIC

Issue 1

Drawing No	Sheets	Rev	Approved date	Title
AD1429	1 to 6	4	02 Apr 2020	Remote Hand Station, ATEX & IECEX Groups IIB & IIC
RS448	1 to 2	1	02 Apr 2020	WINDOW BONDING PROCEDURE
RS308	1 to 2	9	02 Apr 2020	POTTING PROCEDURE FOR CENELEC AND ATEX TERM. BLOCKS / MTR. LOOMS / RHS LOOM