



Certificate no. TAI-FS-C-22-0002 Rev. 01

WE HEREBY CERTIFY THAT

Product description PNEUMATIC SCOTCH-YOKE SPRING RETURN AND
DOUBLE ACTING ACTUATOR

Models SERIES GP/S, GP/D

Manufacturer ROTORK FLUID SYSTEMS S.r.l.
Via Padre Jacques Hamel 138/B
I-55016 Porcari (LU)

IS IN COMPLIANCE WITH THE REQUIREMENTS OF THE STANDARDS

IEC 61508 Parts 1–7:2010

AS RESULT OF THE ASSESSMENT ACCORDING TO THE PROVISION
SET OUT IN THE ABOVE-MENTIONED STANDARDS

Summary Report no. TAI-FS-R-22-0004 Rev. 01

Expiry date 10.01.2025

Issue date 20.03.2023

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.
20.03.2023, Monte Roberto (AN)

Page 1 of 2

Ing. Crescenzo Di Fratta

Annex to certificate no. TAI-FS-C-22-0002 Rev. 01

Type	A
HFT	0
Safety functions	<u>Spring return actuators:</u> 1. Delivery of a full stroke ($90^\circ \pm$ tolerance) driven by the spring, with power fluid exhausted from the cylinder through the control system <u>Double acting actuators:</u> 1. Delivery of a full stroke ($90^\circ \pm$ tolerance) driven by the piston of cylinder, powered by the specified medium working pressure
Mode of operation	High Demand Mode


Random failure rates				
Configuration	Safety function	λ_{DU} [1/h]	λ_{DD} [1/h]	λ_S [1/h]
GP/S - No on-line monitoring	1	8,38E-08	0,00E+00	0,00E+00
GP/S - With on-line monitoring	1	7,54E-09	7,63E-08	0,00E+00
GP/D - No on-line monitoring	1	6,75E-08	0,00E+00	0,00E+00
GP/D - With on-line monitoring	1	6,08E-09	6,15E-08	0,00E+00

Systematic capability	3 (Route 1s applied)			
Architectural constraints	Route 1 _H :	Applied	Route 2 _H :	Applied
	The product can be used in: <ul style="list-style-type: none"> • single channel configuration: <ul style="list-style-type: none"> ○ up to SIL 1 without on-line monitoring by the process ○ up to SIL 3 considering on-line monitoring by the process • double channel configuration: up to SIL 3 			

- Remarks:**
- For further details, including environmental conditions, limitations of use, lifetime, failure rates traceability, mean repair times, common cause factors and systematic capability constraints, make reference to Safety Manual SM-GP-A-02-E.

END OF CERTIFICATE

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.
20.03.2023, Monte Roberto (AN)



Ing. Crescenzo Di Fratta