



Certificate no. TAI-FS-C-21-0069 Rev. 01

WE HEREBY CERTIFY THAT

Product description HYDRAULIC SCOTCH-YOKE SPRING RETURN AND
DOUBLE ACTING ACTUATOR

Models SERIES GH/S, GH/S-FA, GH/D

Manufacturer ROTORK FLUID SYSTEMS S.r.l.
Via Padre Jacques Hamel 138/B
I-55016 Porcari (LU)

IS IN COMPLIANCE WITH THE REQUIREMENTS OF THE STANDARDS

IEC 61508 Parts 1–7:2010

AS RESULT OF THE ASSESSMENT ACCORDING TO THE PROVISION
SET OUT IN THE ABOVE-MENTIONED STANDARDS

Summary Report no. TAI-FS-R-21-0143 Rev. 01

Expiry date 04.07.2024

Issue date 15.03.2022

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.
15.03.2022, Monte Roberto (AN)

Page 1 of 2

Ing. Crescenzo Di Fratta

Annex to certificate no. TAI-FS-C-21-0069 Rev. 01


Type	A
HFT	0
Safety functions	<u>Spring return actuators:</u> 1. Delivery of a full stroke ($90^\circ \pm$ tolerance) driven by the spring, with power fluid exhausted from the cylinder through the control system <u>Double acting actuators:</u> 1. Delivery of a full stroke ($90^\circ \pm$ tolerance) driven by the piston of cylinder, powered by the specified medium working pressure
Mode of operation	Low Demand Mode

Random failure rates				
Configuration	Safety function	λ_{DU} [1/h]	λ_{DD} [1/h]	λ_S [1/h]
GH/S - No PST	1	1,51E-08	0,00E+00	0,00E+00
GH/S - With PST	1	1,36E-09	1,37E-08	0,00E+00
GH/S-FA - No PST	1	1,61E-08	0,00E+00	0,00E+00
GH/S-FA - With PST	1	1,45E-09	1,46E-08	0,00E+00
GH/D - No PST	1	2,12E-08	0,00E+00	0,00E+00
GH/D - With PST	1	1,90E-09	1,93E-08	0,00E+00

Systematic capability	3 (Route 1s applied)			
Architectural constraints	Route 1H:	Applied	Route 2H:	Applied
	The product can be used in: <ul style="list-style-type: none"> • single channel configuration: <ul style="list-style-type: none"> ○ up to SIL 2 without external diagnostic tests ○ up to SIL 3 considering external diagnostic tests • double channel configuration: up to SIL 3 			

- Remarks:**
- For further details, including environmental conditions, limitations of use, lifetime, failure rates traceability, mean repair times, common cause factors and systematic capability constraints, make reference to Safety Manual SM-GH-A-02-E.

END OF CERTIFICATE



Ing. Crescenzo Di Fratta

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.
15.03.2022, Monte Roberto (AN)

Page 2 of 2

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.
 Sede operativa: Via dell'Industria, 14 – 25030 Erbusco - Brescia, Italy
 Phone +39 030 9821049 Fax +39 030 9822253 info.bs@tuvaustralia.com
 Sede legale: Via del Commercio, 6/A - 60030 Monte Roberto - Ancona, Italy
 Cap. Soc. i.v. EUR 10.000,00; R.l. Ancona – C.F. – P. IVA 02217380423
 Cod. Id. CEE IT02217380423 REA AN n. 170070
 A socio unico, soggetta a controllo e coordinamento di:
 TÜV AUSTRIA HOLDING AG, Deutschstrasse 10, 1230, Vienna, Austria
www.tuvaustralia.com www.tuv.at