



Certificate no. TAI-FS-C-24-0065 Rev. 01

WE HEREBY CERTIFY THAT

Product description PNEUMATIC COMPACT SCOTCH-YOKE SPRING RETURN
AND DOUBLE ACTING ACTUATOR

Models SERIES CP/S, CP/D

Manufacturer Rotork Fluid Technology (Suzhou) Co., Ltd.
Building A, No. 88 Yinhe Road
Southeast Street, Changshu, Jiangsu 215558
People's Republic of China

IS IN COMPLIANCE WITH THE REQUIREMENTS OF THE STANDARDS

IEC 61508 Parts 1–7:2010

AS RESULT OF THE ASSESSMENT ACCORDING TO THE PROVISION
SET OUT IN THE ABOVE-MENTIONED STANDARDS

Summary Report no. TAI-FS-R-24-0129 Rev. 01

Expiry date 13.06.2027

Issue date 07.10.2024

TUV AUSTRIA ITALIA
07.10.2024, Monte Roberto (AN)

Ing. Crescenzo Di Fratta

TUV AUSTRIA ITALIA S.p.A.

Via del Commercio, 6/A 60030 Monte Roberto (AN)
+39 0731 22781 - info@tuvaustraliaitalia.com - tuvaustraliaitalia@pec.it
C.F./P. IVA IT01055750333 - Cap. Soc. i.v. € 400.000,00 - REA AN n. 211030
Società a socio unico, soggetta a controllo e coordinamento di:
TUV AUSTRIA HOLDING AG Deutschstrasse 10, A-1230, Vienna, Austria
www.tuvaustraliaitalia.com

Annex to certificate no. TAI-FS-C-24-0065 Rev. 01

Type	A
HFT	0
Safety functions	<u>Spring return actuators:</u> 1. Delivery of a full stroke (90° ± tolerance) driven by the spring, with power fluid exhausted from the cylinder through the control system <u>Double acting actuators:</u> 1. Delivery of a full stroke (90° ± tolerance) driven by the piston of cylinder, powered by the specified medium working pressure
Mode of operation	Low Demand Mode

Random failure rates				
Configuration	Safety function	λ_{DU} [1/h]	λ_{DD} [1/h]	λ_S [1/h]
Series CP/S - No PST	1	2,48E-08	0,00E+00	0,00E+00
Series CP/S - With PST	1	2,23E-09	2,25E-08	0,00E+00
Series CP/D - No PST	1	2,30E-08	0,00E+00	0,00E+00
Series CP/D - With PST	1	2,07E-09	2,10E-08	0,00E+00

Systematic capability	3 (Route 1s applied)			
Architectural constraints	Route 1 _H :	Applied	Route 2 _H :	Applied
	The product can be used in: <ul style="list-style-type: none"> • single channel configuration: <ul style="list-style-type: none"> ○ up to SIL 2 without external diagnostic tests ○ up to SIL 3 considering external diagnostic tests • double channel configuration: up to SIL 3 			

- Remarks:**
- For further details, including environmental conditions, limitations of use, lifetime, failure rates traceability, mean repair times, common cause factors and systematic capability constraints, make reference to Safety Manual SM-CP-A-02-E

END OF CERTIFICATE

TUV AUSTRIA ITALIA
07.10.2024, Monte Roberto (AN)


 Ing. Crescenzo Di Fratta

TUV AUSTRIA ITALIA S.p.A.
 Via del Commercio, 6/A 60030 Monte Roberto (AN)
 +39 0731 22781 - info@tuvaustraiitalia.com - tuvaustraiitalia@pec.it
 C.F./P. IVA IT01055750333 - Cap. Soc. i.v. € 400.000,00 - REA AN n. 211030
 Società a socio unico, soggetta a controllo e coordinamento di:
 TÜV AUSTRIA HOLDING AG Deutschstrasse 10, A-1230, Vienna, Austria
 www.tuvaustraiitalia.com