



**Certificate no. TAI-FS-C-21-0075**

WE HEREBY CERTIFY THAT

**Product description** PNEUMATIC COMPACT SCOTCH-YOKE SPRING RETURN AND DOUBLE ACTING ACTUATOR

**Models** SERIES CP/S, CP/D

**Manufacturer** ROTORK CONTROLS (INDIA) PVT., LTD.  
28B, North Phase, Sidco Industrial Estate  
Ambattur, Chennai, Tamil Nadu 600098  
India

IS IN COMPLIANCE WITH THE REQUIREMENTS OF THE STANDARDS

**IEC 61508 Parts 1–7:2010**

AS RESULT OF THE ASSESSMENT ACCORDING TO THE PROVISION SET OUT IN THE ABOVE-MENTIONED STANDARDS

**Summary Report no. TAI-FS-R-21-0155**

**Expiry date** 04.07.2024

**Issue date** 29.07.2021

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.  
29.07.2021, Monte Roberto (AN)

Page 1 of 2

Ing. Crescenzo Di Fratta

## Annex to certificate no. TAI-FS-C-21-0075

|                          |   |
|--------------------------|---|
| <b>Type</b>              | A   |
| <b>HFT</b>               | 0   |
| <b>Safety functions</b>  | <u>Spring return actuators:</u><br>1. Delivery of a full stroke (90° ± tolerance) driven by the spring, with power fluid exhausted from the cylinder through the control system<br><u>Double acting actuators:</u><br>1. Delivery of a full stroke (90° ± tolerance) driven by the piston of cylinder, powered by the specified medium working pressure |
| <b>Mode of operation</b> | Low Demand Mode   |


| Random failure rates |                 |                      |                      |                   |
|----------------------|-----------------|----------------------|----------------------|-------------------|
| Configuration        | Safety function | $\lambda_{DU}$ [1/h] | $\lambda_{DD}$ [1/h] | $\lambda_S$ [1/h] |
| CP/S - No PST        | 1               | 6,83E-08             | 0,00E+00             | 0,00E+00          |
| CP/S - With PST      | 1               | 6,15E-09             | 6,22E-08             | 0,00E+00          |
| CP/D - No PST        | 1               | 5,77E-08             | 0,00E+00             | 0,00E+00          |
| CP/D - With PST      | 1               | 5,19E-09             | 5,25E-08             | 0,00E+00          |

|                                  |  |         |                        |         |
|----------------------------------|--|---------|------------------------|---------|
| <b>Systematic capability</b>     | 3 (Route 1s applied)   |         |                        |         |
| <b>Architectural constraints</b> | Route 1 <sub>H</sub> :   | Applied | Route 2 <sub>H</sub> : | Applied |
|                                  | The product can be used in: <ul style="list-style-type: none"> <li>• single channel configuration:               <ul style="list-style-type: none"> <li>○ up to SIL 2 without external diagnostic tests</li> <li>○ up to SIL 3 considering external diagnostic tests</li> </ul> </li> <li>• double channel configuration: up to SIL 3</li> </ul> |         |                        |         |

- Remarks:**
- For further details, including environmental conditions, limitations of use, lifetime, failure rates traceability, mean repair times, common cause factors and systematic capability constraints, make reference to Safety Manual SM-CP-A-02-E.

END OF CERTIFICATE

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.  
 29.07.2021, Monte Roberto (AN)



Ing. Crescenzo Di Fratta