



Certificate no. TAI-FS-C-22-0021

WE HEREBY CERTIFY THAT

Product description PNEUMATIC RACK AND PINION SPRING RETURN AND DOUBLE ACTING ACTUATOR

Models SERIES RP/S, RP/D

Manufacturer ROTORK FLUID SYSTEMS S.r.l.
Via Padre Jacques Hamel 138/B
I-55016 Porcari (LU)

IS IN COMPLIANCE WITH THE REQUIREMENTS OF THE STANDARDS

IEC 61508 Parts 1–7:2010

AS RESULT OF THE ASSESSMENT ACCORDING TO THE PROVISION SET OUT IN THE ABOVE-MENTIONED STANDARDS

Summary Report no. TAI-FS-R-22-0043

Expiry date 15.05.2025

Issue date 16.05.2022

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.
16.05.2022, Monte Roberto (AN)

Page 1 of 2

Ing. Crescenzo Di Fratta

Annex to certificate no. TAI-FS-C-22-0021

Type	A
HFT	0
Safety functions	<p><u>Spring return actuators:</u></p> <p>1. Delivery of a full stroke ($90^\circ \pm$ tolerance) driven by the spring, with power fluid exhausted from the cylinder through the control system</p> <p><u>Double acting actuators:</u></p> <p>1. Delivery of a full stroke ($90^\circ \pm$ tolerance) driven by the piston of cylinder, powered by the specified medium working pressure</p>
Mode of operation	Low Demand Mode

Random failure rates				
Configuration	Safety function	λ_{DU} [1/h]	λ_{DD} [1/h]	λ_s [1/h]
RP/S - No PST	1	5,65E-08	0,00E+00	0,00E+00
RP/S - With PST	1	5,08E-09	5,14E-08	0,00E+00
RP/D - No PST	1	5,76E-08	0,00E+00	0,00E+00
RP/D - With PST	1	5,18E-09	5,24E-08	0,00E+00


Systematic capability	3 (Route 1 _s applied)			
Architectural constraints	Route 1_H:	Applied	Route 2_H:	Applied
	<p>The product can be used in:</p> <ul style="list-style-type: none"> • single channel configuration: <ul style="list-style-type: none"> ○ up to SIL 2 without external diagnostic tests ○ up to SIL 3 considering external diagnostic tests • double channel configuration: up to SIL 3 			

Remarks:

- For further details, including environmental conditions, limitations of use, lifetime, failure rates traceability, mean repair times, common cause factors and systematic capability constraints, make reference to Safety Manual SM-RP-A-01-E.

END OF CERTIFICATE

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.
16.05.2022, Monte Roberto (AN)



Ing. Crescenzo Di Fratta