



Certificate no. TAI-FS-C-22-0013

WE HEREBY CERTIFY THAT

Product description HYDRAULIC LINEAR SPRING RETURN AND DOUBLE ACTING ACTUATOR

Models SERIES LH/S, LH/D

Manufacturer ROTORK FLUID SYSTEMS S.r.l.
Via Padre Jacques Hamel 138/B
I-55016 Porcari (LU)

IS IN COMPLIANCE WITH THE REQUIREMENTS OF THE STANDARDS

IEC 61508 Parts 1–7:2010

AS RESULT OF THE ASSESSMENT ACCORDING TO THE PROVISION SET OUT IN THE ABOVE-MENTIONED STANDARDS

Summary Report no. TAI-FS-R-22-0027

Expiry date 04.05.2025

Issue date 05.05.2022

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.
05.05.2022, Monte Roberto (AN)

Page 1 of 2

Ing. Crescenzo Di Fratta

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.
Sede operativa: Via dell'Industria, 14 - 25030 Erbusco - Brescia, Italy
Phone +39 030 9821049 Fax +39 030 9822253 info.bs@tuvaustritalia.com
Sede legale: Via del Commercio, 6/A - 60030 Monte Roberto - Ancona, Italy
Cap. Soc. i.v. EUR 10.000,00; R.I. Ancona - C.F. - P. IVA 02217380423
Cod. Id. CEE IT02217380423 REA AN n. 170070
A socio unico, soggetta a controllo e coordinamento di:
TÜV AUSTRIA HOLDING AG, Deutschstrasse 10, 1230, Vienna, Austria
www.tuvaustriaitalia.com www.tuv.at

Annex to certificate no. TAI-FS-C-22-0013

Type	A
HFT	0
Safety functions	1. Stem extended upon the demand of the actuation system 2. Stem retracted upon the demand of the actuation system
Mode of operation	Low Demand Mode

Random failure rates				
Configuration	Safety function	λ_{DU} [1/h]	λ_{DD} [1/h]	λ_S [1/h]
LH/SD - No PST	1	2,38E-08	0,00E+00	0,00E+00
LH/SD - With PST	1	2,38E-09	2,15E-08	0,00E+00
LH/SU - No PST	2	2,41E-08	0,00E+00	0,00E+00
LH/SU - With PST	2	2,41E-09	2,17E-08	0,00E+00
LH/FD - No PST	1	4,94E-08	0,00E+00	0,00E+00
LH/FD - With PST	1	4,94E-09	4,44E-08	0,00E+00
LH/FU - No PST	2	4,82E-08	0,00E+00	0,00E+00
LH/FU - With PST	2	4,82E-09	4,34E-08	0,00E+00


Systematic capability	3 (Route 1s applied)			
Architectural constraints	Route 1_H:	Applied	Route 2_H:	Applied
	The product can be used in:			
	<ul style="list-style-type: none"> • single channel configuration: <ul style="list-style-type: none"> ○ up to SIL 2 without external diagnostic tests ○ up to SIL 3 considering external diagnostic tests • double channel configuration: up to SIL 3 			

Remarks:

- The above random failure rates values are worst-case values for all the possible configurations.
- For further details, including environmental conditions, limitations of use, lifetime, failure rates traceability, mean repair times, common cause factors and systematic capability constraints, make reference to Safety Manual SM-LH-A-01-E.

END OF CERTIFICATE

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.
05.05.2022, Monte Roberto (AN)



Ing. Crescenzo Di Fratta