

**Certificate of Conformity No.: 28716198**

**Manufacturer: Rotork Controls, Inc.**  
675 Mile Crossing Blvd.  
Rochester, NY 14624  
United States of America

**Specifications: IEC 61508-1÷7:2010**

**Product: Hydraulic linear spring return actuator**

**Type: Series LH/S**

**RESULT:**

As per the TÜV Rheinland Italia Report No. FS 28716198 Rev. 0, we declare that the product meets the below requirements:

**IEC 61508: 2010, part 1 to 7**

**Functional Safety of electrical/electronic/programmable electronic safety related systems; Type A, Low Demand Mode, HFT=0**

| Model | Safety Action                  | $\lambda_D$<br>[1/h] | $\lambda_{DD(PS)}$<br>[1/h] | Systematic Capability |
|-------|--------------------------------|----------------------|-----------------------------|-----------------------|
| LH/SD | Stem extended<br>(Spring down) | 1,26E-08             | 1,14E-08                    | 3                     |
| LH/SU | Stem retracted<br>(Spring up)  | 1,28E-08             | 1,16E-08                    | 3                     |

The above values are compatible with SIL 3.

The requirements of minimum hardware fault tolerance (HFT) according to par. 11.4.3 of IEC 61511-1 have to be observed.

The product can be used up to SIL 2 without external diagnostics.

For further details, see what written in the Safety Manual.

**Expiry date: 2019-03-31**

--- End page

Location **Milan**  
Date **2016-07-08**

Diego Sirtori  
Business Stream Manager





Attachment 1 to  
 Certificate of Conformity No.: 28716198



**Manufacturer:** Rotork Controls, Inc.  
 675 Mile Crossing Blvd.  
 Rochester, NY 14624  
 United States of America

**Specifications:** IEC 61508-1÷7:2010

**Product:** Hydraulic linear spring return actuator

**Type:** Series LH/S – Model LH/SD

|                                   |    | Test Interval Frequency (months) |          |          |          |          |
|-----------------------------------|----|----------------------------------|----------|----------|----------|----------|
|                                   |    | 6                                | 12       | 24       | 36       | 48       |
| Partial Stroke frequency (months) | 1  | 7,19E-06                         | 9,95E-06 | 1,55E-05 | 2,10E-05 | 2,65E-05 |
|                                   | 2  | 1,13E-05                         | 1,41E-05 | 1,96E-05 | 2,51E-05 | 3,06E-05 |
|                                   | 3  | 1,55E-05                         | 1,82E-05 | 2,37E-05 | 2,92E-05 | 3,47E-05 |
|                                   | 6  |                                  | 3,06E-05 | 3,61E-05 | 4,16E-05 | 4,71E-05 |
|                                   | 9  |                                  |          |          | 5,40E-05 |          |
|                                   | 12 |                                  |          | 6,09E-05 | 6,64E-05 | 7,19E-05 |

PFD<sub>AVG</sub> values according to IEC 61508 for different values of TI and TI<sub>PS</sub>

| Test Interval Frequency (months) |          |          |          |          |
|----------------------------------|----------|----------|----------|----------|
| 6                                | 12       | 24       | 36       | 48       |
| 2,79E-05                         | 5,54E-05 | 1,11E-04 | 1,66E-04 | 2,21E-04 |

PFD<sub>AVG</sub> values according to IEC 61508 for different values of TI (no Partial Stroke Test)

NOTES:

- The above values of PFD<sub>AVG</sub> are calculated for MRT=24 h and Proof Test Coverage=100%. For other values of MRT, TI, TI<sub>PS</sub> and/or non-perfect Proof Test, the PFD<sub>AVG</sub> values must be re-calculated.
- The PFD<sub>AVG</sub> values including Partial Stroke Test are calculated considering the use of a commercial automatic Partial Stroking Test System: for further details, see the Safety Manual.

--- End page





Attachment 2 to  
 Certificate of Conformity No.: 28716198



**Manufacturer:** Rotork Controls, Inc.  
 675 Mile Crossing Blvd.  
 Rochester, NY 14624  
 United States of America

**Specifications:** IEC 61508-1÷7:2010

**Product:** Hydraulic linear spring return actuator

**Type:** Series LH/S – Model LH/SU

|                                   |    | Test Interval Frequency (months) |          |          |          |          |
|-----------------------------------|----|----------------------------------|----------|----------|----------|----------|
|                                   |    | 6                                | 12       | 24       | 36       | 48       |
| Partial Stroke frequency (months) | 1  | 7,31E-06                         | 1,01E-05 | 1,57E-05 | 2,13E-05 | 2,69E-05 |
|                                   | 2  | 1,15E-05                         | 1,43E-05 | 1,99E-05 | 2,55E-05 | 3,11E-05 |
|                                   | 3  | 1,57E-05                         | 1,85E-05 | 2,41E-05 | 2,97E-05 | 3,53E-05 |
|                                   | 6  |                                  | 3,11E-05 | 3,67E-05 | 4,23E-05 | 4,79E-05 |
|                                   | 9  |                                  |          |          | 5,49E-05 |          |
|                                   | 12 |                                  |          | 6,19E-05 | 6,75E-05 | 7,31E-05 |

PFD<sub>AVG</sub> values according to IEC 61508 for different values of TI and TI<sub>PS</sub>

| Test Interval Frequency (months) |          |          |          |          |
|----------------------------------|----------|----------|----------|----------|
| 6                                | 12       | 24       | 36       | 48       |
| 2,83E-05                         | 5,63E-05 | 1,12E-04 | 1,68E-04 | 2,24E-04 |

PFD<sub>AVG</sub> values according to IEC 61508 for different values of TI (no Partial Stroke Test)

NOTES:

- The above values of PFD<sub>AVG</sub> are calculated for MRT=24 h and Proof Test Coverage=100%. For other values of MRT, TI, TI<sub>PS</sub> and/or non-perfect Proof Test, the PFD<sub>AVG</sub> values must be re-calculated.
- The PFD<sub>AVG</sub> values including Partial Stroke Test are calculated considering the use of a commercial automatic Partial Stroking Test System: for further details, see the Safety Manual.

-----End certificate

