

Certificate of Compliance

Certificate: 1169596 (LR 40749)

Master Contract: 153247

Project: 1169596

Date Issued: 2001-6-27

Issued to: Rotork Controls Inc.
675 Mile Crossing Blvd.
Rochester NY 14624
USA


Attention: Mr. Tim White

The products listed below are eligible to bear the CSA Mark shown



Issued by:


Ray Lehman

Authorized by: 
Ray Fadavi, P. Eng., MBA
Operations Manager

PRODUCTS

CLASS 3221 02 - VALVES - Actuators

Connection Box for use with Actuators, Model Pakbox PB1 MK2, rated up to 600Vac, 20 A, 60Hz, 3 phase or up to 600Vac, 7.5 A, 60Hz, 1 phase, Enclosure CSA Type 4X.

Connection Box for use with Actuators, Model Pakbox PB2 MK2, rated input 120V ac, 20mA, 60Hz; output relay (RLY1 to RLY5) contacts rated 0.4A, 125V ac or 2A, 30V dc, Enclosure CSA Type 4X.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No.	139-1982	-	Electrically Operated Valves
CAN/CSA-C22.2 No.	94-M91	-	Special Purpose Enclosures