



GROUP II

1 CERTIFICATE OF CONFORMITY - Apparatus

2 Certificate No. Sira Ex 98E1275

3 This Certificate is issued for the electrical apparatus:

Mk II Pak-Box, switch assembly and terminal box

4a Manufactured by:

Rotork Controls Ltd
Brassmill Lane
Bath
Avon
BA1 3JQ

4b Submitted for certification by:

The Manufacturer

5 This electrical apparatus and any acceptable variation thereto is specified in the schedule to this Certificate and the documents therein referred to.

6 Sira Certification Service being an Approved-Certification Body in accordance with Article 14 of Directive 76/117/EEC of the Council of the European Communities of 18 December 1975 certifies that the apparatus has been found to comply with the following harmonised European Standards:

EN 50014:1992
EN 50018:1994
EN 50019:1994


The assessment and test results are recorded in Sira Test Report R51X4582A.

7 The apparatus marking shall include the code:

EEx d IIB T4 (T_{amb} = -30°C to +70°C) (switch variant)
EEx de IIB T4 (T_{amb} = -30°C to +70°C) (terminal variant with control enclosure)

Dated 16 February 1999

File No. 51X4582
C.Index 04


M D Shearman
Certification Manager

This certificate and its schedules may only be reproduced in its entirety and without change