

Certificate of Conformance **RC200-Arctic actuators**

This document certifies the testing of RC200-range in arctic version.

The actuators including manual override unit are tested in -47°C with full functionality. They are mechanically designed for usage down to -55°C.

Falun 2010-10-11



Stefan Nordström
Design engineer
Rotork Sweden AB

Pneumatic, Electric and Hydraulic Valve Actuators & Accessories

POSTADDRESS
Rotork Sweden AB
P.O.Box 80, Kontrollvägen 15
SE-791 22 FALUN
Sweden

TELEFON
+46 (0)23 587 00

TELEFAX
+46 (0)23 587 45

ISO 9001
BUREAU VERITAS
Certification



ISO 14001
BUREAU VERITAS
Certification



SÄTE
Falun

Org.No. 556061-3670

BANK
Nordea, Falun

info@remotecontrol.se
www.rotork.com