

FM Approvals  
1151 Boston Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com



# CERTIFICATE OF COMPLIANCE

## HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

**Actuator Setting Tool Pro Model BTST**

IS/I/1/ABCD/T4 Ta = 50°C

*Specific Condition of Use: When used with four AAA Duracell Procell MN2400 or four AAA Energizer E92 batteries*

**Equipment Ratings:**

Intrinsically Safe apparatus suitable for installation in Class I, Division 1, Groups A, B, C, and D;  
Temperature Class T4 Ta = 50°C; indoor Hazardous (Classified) Locations.

**FM Approved for:**

Rotork Controls Ltd.  
Brassmill Lane  
Bath, Somerset, BA1 3JQ  
United Kingdom



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3610	2010
Class 3810	2005

Original Project ID: 3039072

Approval Granted: *September 7, 2010*

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC

  
\_\_\_\_\_  
J.E. Marquedan  
Group Manager, Electrical

*7 September 2010*  
Date