



# Certificate of Compliance

Certificate: 2291170

Master Contract: 153247

Project: 2291170

Date Issued: January 13, 2011

Issued to: Rotork Controls Inc.  
675 Mile Crossing Blvd  
Rochester, NY 14624  
USA  
Attention: Tim White

*The products listed below are eligible to bear the CSA Mark shown*



*Ron Wildish*

Issued by: Ron Wildish

## PRODUCTS

**CLASS 2258 03 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe and Non - Incendive Systems - For Hazardous Locations**

**Class I, Div. 1, Group A, B, C, D:**

Model *PRO* BTST Bluetooth® Actuator Setting Tool; intrinsically safe, hand-held-portable, battery operated (four 1.5 V “AAA” size Duracell, Procell Type MN2400 or Eveready Energizer, Type E92 Alkaline-Manganese or Zinc-Manganese cells); Temperature Code T4; Ambient: -30°C to +50°C.

## APPLICABLE REQUIREMENTS

**CAN/CSA-C22.2 No. 0-M91 - General Requirements – Canadian Electrical Code, Part II**

**CAN/CSA-C22.2 No. 157-92 - Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations**

**UL 913 (7th Ed.) - Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II and III, Division I, Hazardous Locations**



## *Supplement to Certificate of Compliance*

Certificate: 2291170

Master Contract: 153247

*The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.*

### Product Certification History

---

Project	Date	Description
2291170	January 13, 2011	Model PRO BTST Bluetooth® Actuator Setting Tool; I.S. for Class I, Division 1, Groups A,B,C,D.