

# 防爆合格证

证号: GYJ18.1036X

由 Rotork Instruments Italy srl 制造的产品:  
(地址: Via Portico 17, 24050 Orio al Serio (BG), Italy)

名称 Rotary Limited Switch Boxes

型号规格 SOLDOTM SW系列, SY系列

防爆标志 Ex d IIC T4~T6 Gb, Ex tD A21 IP68 T140°C/T110°C

产品标准 /

图样编号 SL0225141-03, SL0225142-04

经图样及技术文件的审查和样品检验, 确认上述产品符合 GB 3836.1-2010、GB 3836.2-2010、GB 12476.1-2013、GB 12476.5-2013 标准, 特颁发此证。

本证书有效期: 2018年1月30日至2023年1月29日

备注 1. 安全使用注意事项见本证书附件。  
2. 证书编号后缀“X”表明产品具有安全使用特殊条件, 内容见本证书附件。

站长

国家级仪器仪表防爆安全监督检验站


颁发日期二〇一八年一月三十日

本证书仅对与认可文件和样品一致的产品有效。

地址: 上海市漕宝路103号  
邮编: 200233

网址: www.nepsi.org.cn  
Email: info@nepsi.org.cn

电话: +86 21 64368180  
传真: +86 21 64844580



# EXPLOSION PROTECTION CERTIFICATE OF CONFORMITY

Cert NO.GYJ18.1036X

This is to certify that the product

Rotary Limited Switch Boxes

manufactured by Rotork Instruments Italy srl

(Address: Via Portico 17, 24050 Orio al Serio (BG), Italy)

which model is SOLDO™ SW Series, SY Series

Ex marking Ex d II C T4~T6 Gb, Ex tD A21 IP68 T140°C/T110°C

product standard /

drawing number SL0225141-03, SL0225142-04

has been inspected and certified by NEPSI, and that it conforms  
to GB 3836.1-2010, GB 3836.2-2010, GB 12476.1-2013, GB 12476.5-2013

This Approval shall remain in force until 2023.01.29

**Remarks** 1. Conditions for safe use are specified in the attachment(s) to this certificate.  
2. Symbol "X" placed after the certification number denotes specific conditions of use,  
which are specified in the attachment(s) to this certificate.

Director



National Supervision and Inspection Centre for  
Explosion Protection and Safety of Instrumentation

Issued Date 2018.01.30

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.

103 Cao Bao Road  
Shanghai 200233, China

<http://www.nepsi.org.cn>  
Email: [info@nepsi.org.cn](mailto:info@nepsi.org.cn)

Tel: +86 21 64368180  
Fax: +86 21 64844580