

The manufacturer may use the mark:



Revision 3.2 January 12, 2024 Surveillance Audit Due October 1, 2026



## Certificate / Certificat Zertifikat / 合格証

BIF 1705128 C002

exida hereby confirms that the:

# FP02G and FP05G Series Gas Service Solenoid Valves

### Bifold Fluidpower Ltd. Chadderton, Manchester – UK

Have been assessed per the relevant requirements of:

IEC 61508: 2010 Parts 1-2

and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2<sub>H</sub> Device

PFH/PFD<sub>avg</sub> and Architecture Constraints must be verified for each application

### Safety Function:

The Solenoid Valves will vent the service port pressure when de-energized within the specified safety time.

### Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



**Evaluating Assessor** 

Certifying Assessor

# Certificate / Certificat / Zertifikat / 合格証

BIF 1705128 C002

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2<sub>H</sub> Device

PFH/PFD<sub>avg</sub> and Architecture Constraints must be verified for each application

#### **Systematic Capability:**

These products have met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

#### **Random Capability:**

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets exida criteria for Route  $2_H$ .

#### Versions:

Valve Types	Description and Application		
FP02G and FP05G	3 Port, 2 Position Normally Closed/Open Solenoid		
	Valve for Gas Service, De-Energize to Trip (DTT)		
	Applications		
Options Included for the above Models:	Single Type 74, 77 and 78 or Type 58 Solenoid		
	Operator		
	DC or AC (Wiring Option 1) Coil up to 10W		
	Up to 690 Bar Max Working Pressure		
	Spring Return and Detented Manual Override		

#### IEC 61508 Failure Rates in FIT1

Device/Application/Configuration	λ <sub>SD</sub>	λѕυ	$\lambda_{ extsf{DD}}$	λου
FP02G and FP05G; NC, DTT	0	179	0	137
FP02G and FP05G; NO, DTT	0	128	0	183

<sup>&</sup>lt;sup>1</sup> FIT = 1 failure / 10<sup>9</sup> hours

#### SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD<sub>avg</sub> considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: BIF 17/05-128 R002 V2 R4 (or later)

Safety Manual: SM.0002 Rev 3 of later





80 N Main St Sellersville, PA 18960

T-061, V5R2